

Broszura informacyjna dla wytwórców energii z instalacji OZE

Zgłaszanie wyłączeń i ograniczeń mocy w systemie ONS

Wprowadzenie

Niniejsza broszura została przygotowana z myślą o Wytwórcach energii z instalacji OZE współpracujących z Respect Energy. Zawiera kluczowe informacje dotyczące prawidłowego i sprawnego zgłaszania wyłączeń oraz ograniczeń mocy w systemie ONS, a także zasad tworzenia zgłoszeń REMIT.

Celem dokumentu jest ułatwienie przygotowania zgłoszeń kompletnych, poprawnych i możliwych do szybkiej akceptacji.

Dostęp do systemu

Portal ONS:

<https://remit.systemyre.pl/accounts/login/>

Nie posiadają Państwo konta?

Prosimy o kontakt – pomożemy w jego założeniu.

Najważniejsze zasady

- Wyłączenia związane z ujemnymi cenami energii na RDN FIX1 nie wymagają zgłoszenia do systemu ONS, o ile w umowie zawarty jest zapis przewidujący automatyczne wyłączenie instalacji przy ujemnych cenach energii.
- Zgłoszenia należy składać dla każdego planowanego lub nieplanowanego wyłączenia oraz ograniczenia mocy.
- Aby możliwa była edycja zgłoszenia, musi ono posiadać status Active.
- Po zakończeniu zdarzenia należy zmienić status zgłoszenia na Confirmed i ustawić właściwą datę zakończenia zdarzenia.

Co musi zawierać zgłoszenie REMIT?

Każde zgłoszenie REMIT musi zawierać:

- Kod PPE
- Datę i godzinę rozpoczęcia zdarzenia
- Datę zakończenia zdarzenia
jeżeli data zakończenia jest nieznana – należy podać datę orientacyjną i pozostawić zgłoszenie w statusie Active
- Wielkość ubytku mocy (Outage) – w MW
Opcjonalnie – Krótki opis przyczyny zdarzenia (np. awaria, prace serwisowe)

Brak któregokolwiek z powyższych elementów skutkuje odrzuceniem zgłoszenia.

Przykład

Instalacja o mocy 20 MW (10 × 2 MW)

Wyłączenie 2 turbin = ubytek mocy 4 MW

→ w zgłoszeniu należy wpisać: **Outage: 4 MW**

Informational brochure for renewable energy producers

Reporting outages and power limitations in the ONS

Introduction

This brochure has been prepared for renewable energy producers operating RES installations in cooperation with Respect Energy. It contains key information on the correct and efficient reporting of outages and power limitations in the ONS system, as well as the rules for creating REMIT notifications.

The purpose of this document is to facilitate the preparation of notifications that are complete, accurate, and can be approved quickly.

Access to the system

ONS Portal:

<https://remit.systemyre.pl/accounts/login/>

Don't have an account?

Please contact us – we will help you set one up.

Key principles

- Outages related to negative energy prices on the RDN FIX1 market do not need to be reported in the ONS system, provided that the agreement includes a clause allowing automatic shutdown of the installation in case of negative energy prices.
- Notifications must be submitted for every planned or unplanned outage and for any power limitation.
- To enable editing, a notification must have the status Active.
- After the event has ended, the notification status should be changed to Confirmed and the correct end date of the event should be set.

What must a REMIT notification include?

Each REMIT notification must include:

- PPE code
- Start date and time of the event
- End date of the event
If the end date is unknown, provide an estimated date and keep the notification status Active
- Power loss (Outage) – in MW
Optional – a brief description of the cause of the event (e.g., failure, maintenance work)

Omitting any of the above elements will result in the notification being rejected.

Example:

An installation with a capacity of 20 MW (10 × 2 MW)

Shutdown of 2 turbines = power loss of 4 MW

→ The notification should indicate: **Outage: 4 MW**

Kiedy zgłaszać?

Planowane wyłączenia:

- niezwłocznie, zgodnie z zapisami umowy

Nieplanowane wyłączenia:

- jak najszybciej, bez zbędnej zwłoki,
- nawet jeśli zdarzenie już się zakończyło,
- nie później niż do końca okresu rozliczeniowego.

Zmiana zgłoszeń w systemie

W przypadku zmiany planowanego wyłączenia lub ograniczenia mocy należy zaktualizować zgłoszenie poprzez edycję istniejącego wpisu.

Uwaga: edycja zgłoszenia jest możliwa wyłącznie wtedy, gdy posiada ono status Active.

Przykład:

Planowane prace serwisowe obniżają moc instalacji z 10 MW do 8 MW w dniu 21.09.2025 w godzinach 8:00–12:00. Należy zgłosić ograniczenie mocy o 2 MW.

Jeżeli czas trwania lub skala ograniczenia ulegną zmianie, zgłoszenie należy odpowiednio zmodyfikować.

Przykładowo: w przypadku wydłużenia prac o 2 godziny, zgłoszenie powinno obejmować ograniczenie 2 MW w okresie 21.09.2025, godz. 8:00–14:00.

Zatwierdzanie zgłoszeń w systemie

- Każde zgłoszenie (REMIT) powinno ostatecznie zostać oznaczone statusem Confirmed.
- Jeżeli dane zgłoszenia mogą jeszcze ulec zmianie (np. nieznana godzina zakończenia awarii), status Confirmed należy ustawić dopiero po przywróceniu instalacji do normalnej pracy.
- Zgłoszeń w statusie Confirmed nie można już edytować.

Anulowanie zgłoszeń w systemie

W przypadku błędnego wprowadzenia zgłoszenia lub odwołania planowanego ograniczenia, zgłoszenie REMIT należy anulować poprzez ustawienie statusu Cancelled.

Uwaga: anulować można wyłącznie zgłoszenia posiadające status Active.

Kontakt:

W przypadku pytań dotyczących platformy ONS prosimy o kontakt:
prognoza@respect.energy

When to report?

Planned outages:

- Immediately, in accordance with the terms of the agreement.

Unplanned outages:

- As soon as possible, without unnecessary delay,
- even if the event has already ended,
- and no later than the end of the settlement period.

Modifying notifications in the system

In the case of a change to a planned outage or power limitation, the notification must be updated by editing the existing entry.

Note: Editing is only possible if the notification has the status Active.

Example:

Planned maintenance reduces the installation's capacity from 10 MW to 8 MW on 21.09.2025 between 08:00–12:00. A power limitation of 2 MW should be reported.

If the duration or extent of the limitation changes, the notification must be updated accordingly.

For example, if the maintenance is extended by 2 hours, the notification should reflect a 2 MW limitation for 21.09.2025, 08:00–14:00.

Confirming notifications in the system

- Every REMIT notification should ultimately be marked with the status Confirmed.
- If the notification details may still change (e.g., unknown end time of a failure), the Confirmed status should be set only after the installation has returned to normal operation.
- Notifications with the Confirmed status can no longer be edited.

Cancelling notifications in the system

In the case of an incorrectly submitted notification or the cancellation of a planned limitation, the REMIT notification must be cancelled by setting the status to Cancelled.

Note: Only notifications with the status Active can be cancelled.

Contact:

For any questions regarding the ONS platform, please contact:
prognoza@respect.energy